

covering the invention, and explained the concerns for potentially freezing temperatures. The invention identifies the critical parameters where if a threshold is reached, the water flow turns off. Specifically, if the water falls to a temperature of about 38° F, if a higher pressure is detected due to freezing, water flow is turned off. The cited prior art does not teach such protective system.

### REMARKS

All of the pending claims hereof have been amended in an earnest effort to bring out the essence of the invention, where the amendments are believed to be appropriate and do not introduce new matter to the application.

All of the rejected claims stand rejected over the patent to Faulk (USP No. 5,568,825) under the provisions of 35 U.S.C. 102 and 103, alone or in combination with secondary references.

Faulk, as reiterated to the Examiner at the conference, relates to a system for detecting leakage and unwanted flow in a fluid supply within a building capable of detecting small leaks and shutting off flow when a leak occurs. This is a system to maintain the integrity of the system for certainly water leaks can

BEST AVAILABLE COPY